

ADDENDUM NO. 3

Date: April 15, 2022

Project: IPE Space Renovations
University of Southern Maine, Portland Campus
Portland, Maine

This addendum is issued prior to receipt of the bids and does hereby become a part of the contract documents, and in case of conflict, it shall supersede original project manual and drawings. Each bidder shall be responsible for issuing information contained herein to sub-contractors and suppliers to ensure that their proposal covers all work required by the contract documents including this addendum.

1– Questions and Responses:

Q1 – Room C078B calls for VCT-1 as the Wall Base. Is this meant to be RB-1?

R1 – Revise the Finish Schedule on drawing A601 to indicate Wall Base in Room C078B to be RB-1.

Q2 – Is there a pattern for room that contain both VCT-1 & VCT-2?

R2 – Drawing A-602 defines the limits of VCT-1 and VCT-2 for areas where both are specified.

Q3 – Room C082 calls for RT-1. I don't see material description of what RT-1 is. Can you provide it?

R3 – Revise the Finish Schedule on drawing A601 to indicate Flooring in Room C082 to be VCT-1 as shown on A602.